



Scale = 1:26.3 TOTAL WEIGHT = 40 lb [M][F]

LUMBER		N. L. G. A. RULES		LUMBER		DESCR.	
CHORDS	SIZE	DRY	No.2	SPF			
A - C	2x4	DRY	No.2	SPF			
C - E	2x4	DRY	No.2	SPF			
B - D	2x4	DRY	No.2	SPF			
ALL WEBS		2x4	DRY	No.2	SPF		
DRY, SEASONED LUMBER.							

PLATES (table is in inches)		W		LEN		Y		X	
JT	TYPE	PLATES							
B	TMBMH1-m	MT20	5.0	6.0	2.50	0.50			
C	TTW-p	MT20	4.0	4.0					
D	TMBMH1-m	MT20	5.0	6.0	2.50	0.50			
F	BMW+w	MT20	2.0	4.0					

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER									
BEARINGS									
JT	VERT	HORZ	DOWN	HORZ	UPLIFT	IN-SX	IN-SX	HEEL	WEDGE
B	991	0	991	0	0	3-8	3-8	2x4 L	
D	991	0	991	0	0	3-8	3-8	2x4 R	

UNFACTORED REACTIONS							
JT	COMBINED	SNOW	LIVE	PERM.LIVE	WIND	DEAD	SOIL
B	685	539/0	0/0	0/0	0/0	146/0	0/0
D	685	539/0	0/0	0/0	0/0	146/0	0/0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) B, D

BRACING
 TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 4.75 FT.
 MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING
 TOTAL LOAD CASES: (4)

CHORDS		FACTORED		WEBS	
MEMB.	FORCE (LBS)	VERT. LOAD (PLF)	LC1 MAX (LC)	MEMB.	FORCE (LBS)
FR-TO		FROM	TO	FR-TO	
A-B	0/0	-109.6	-109.6 0.06 (1)	10.00	F-C 0/244
B-H	-1317/0	-109.6	-109.6 0.34 (1)	5.22	G-H -327/87
H-C	-1347/0	-109.6	-109.6 0.60 (1)	4.75	I-J -327/87
C-J	-1347/0	-109.6	-109.6 0.60 (1)	4.75	
J-D	-1317/0	-109.6	-109.6 0.34 (1)	5.22	
D-E	0/0	-109.6	-109.6 0.06 (1)	10.00	

MEMB.	FORCE (LBS)	VERT. LOAD (PLF)	LC1 MAX (LC)
B-G	0/1263	-17.5	-17.5 0.49 (1)
G-F	0/1263	-17.5	-17.5 0.49 (1)
F-I	0/1263	-17.5	-17.5 0.49 (1)
I-D	0/1263	-17.5	-17.5 0.49 (1)

DESIGN CRITERIA	
SPECIFIED LOADS:	
TOP CH. LL	= 34.1 PSF
DL	= 3.0 PSF
BOT CH. LL	= 0.0 PSF
DL	= 7.0 PSF
TOTAL LOAD	= 44.0 PSF
SPACING = 24.0 IN. C/C	
THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010	
THIS DESIGN COMPLIES WITH:	
- PART 9 OF OBC 2012, BCBC 2012, ABC 2014	
- CSA 086-09	
- TPIC 2011	
(55% OF 54.3 P.S.F. G.S.L. PLUS 4.2 P.S.F. RAIN LOAD) EQUALS 34.1 P.S.F. SPECIFIED ROOF LIVE LOAD	
ALLOWABLE DEFL.(LL)	= L/360 (0.47")
CALCULATED VERT. DEFL.(LL)	= L/999 (0.07")
ALLOWABLE DEFL.(TL)	= L/360 (0.47")
CALCULATED VERT. DEFL.(TL)	= L/999 (0.13")
CSI: TC=0.60/1.00 (C-H:1), BC=0.49/1.00 (F-G:1), WB=0.04/1.00 (C-F:1), SSI=0.31/1.00 (D-J:1)	
DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10	
COMP=1.10 SHEAR=1.10 TENS=1.10	
COMPANION LIVE LOAD FACTOR = 0.50	
TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.	
NAIL VALUES	
PLATE GRIP(DRY) (PSI)	SHEAR SECTION (PLI) (PLI)
MAX MIN	MAX MIN
MT20 618 354	1667 822 2284 1656
PLATE PLACEMENT TOL. = 0.250 inches	
PLATE ROTATION TOL. = 5.0 Deg.	
JSI GRIP= 0.83 (B) (INPUT = 0.90)	
JSI METAL= 0.34 (B) (INPUT = 1.00)	

